

SEWAGE DISPOSAL

Town of Theresa

Appendix A Separation Distances from Wastewater System Components

| System Components | Well or Suction Line (feet) | To Stream, Lake, Watercourse ^(b) , or Wetland (feet) | Dwelling (feet) | Property Line (feet) |
|---------------------------------------|------------------------------------|---|-----------------|----------------------|
| House sewer (watertight joints) | 25 if cast iron pipe, 50 otherwise | 25 | 3 | 10 |
| Septic tank | 50 | 50 | 10 | 10 |
| Effluent line to distribution box | 50 | 50 | 10 | 10 |
| Distribution box | 100 | 100 | 20 | 10 |
| Absorption field | 100 ^(a) | 100 | 20 | 10 |
| Dry well (roof and footing) | 50 | 25 | 20 | 10 |
| Raised or mound system ^(c) | 100 ^(a) | 100 | 20 | 10 |
| Composter | 50 | 50 | 20 | 10 |

NOTES:

- (a) When sewage treatment systems are located in coarse gravel or upgrade and in the general path of drainage to a well, the closest part of the treatment system shall be at least 200 feet away from the well.
- (b) Mean high water mark.
- (c) For all systems involving the placement of fill material, separation distances are measured from the toe of slope of the fill.